

PLANT ITEM No. 24590-PTF-MV-TCP-VSL-00001

Project:	RPP-WTP	24590-PTF-M6-TCP-P0001		
Project No:	24590	Process Calculation	Deleted /2	
Project Site:	Hanford	Vessel Drawing	24590-PTF-MV-TCP-P0002	
Description:	Treated LAW Concentrate Storage Vessel			

Reference Data


Charge Vessels Tag Numbers	Not Applicable
Pulsejet Mixers / Agitators Tag Numbers	TCP-PJM-00001, TCP-PJM-00002, TCP-PJM-00003, TCP-PJM-00004, TCP-PJM-00005,
	TCP-PJM-00006, TCP-PJM-00007, TCP-PJM-00008
RFDs/Pumps Tag Numbers	Not Applicable

Design Data

Quality Level		СМ	Fabrication Specs	24590-WTP-31	PS-MV00-TP001	
Seismic Category		SC-III	Design Code	ASME VIII Div 1		
Service/Contents		Radioaçtive Liquid	Code Stamp	Yes		
Design Specific Gravity		1.57 /2	NB Registration	Yes		
Maximum Operating Volume	gal	129,963 /2	Weights (lbs)	Empty	Operating	Test
Total Volume	gal	146,740	Estimated	240,500	2,005,100	1,469,300
	•		Actual *			

Inside Diameter	inch	318			Wind Design	Not	Required	
Length/Height (TL-TL) inch 362		Snow Design	Not Required					
•				Coil/Jacket	Seismic Design	24590-WTP-3PS-FB01-T0001		
		Operating	<u>Design</u>	<u>Design</u>		245	90-WTP-3PS-MV00-TP002	
Internal Pressure	psig	0 ^	15	NIA	Seismic Base Moment *	ft*lb		
External Pressure	psig	0.22/2	8 _^	NIA	Postweld Heat Treat	Not	Required	
Temperature	°F	212/2	237/2	N/A	Corrosion Allowance	Inch	0.04 (Notes 7 & 8) /2	
Min. Design Metal Temp.	°F	40			Hydrostatic Test Pressure *	psig		

Note: Please note that source, special nuclear and byproduct materials, as defined in the Atomic Energy Act of 1954 (AEA), are regulated at the U.S. Department of Energy (DOE) facilities exclusively by DOE acting pursuant to its AEA authority. DOE asserts, that pursuant to the AEA, it has sole and exclusive responsibility and authority to regulate source, special nuclear, and byproduct materials at DOE-owned nuclear facilities. Information contained herein on radionuclides is provided for process description purposes only.



This Bound Document Contains a total of 5 Sheets.

			AL.	Î	DI	200
2	1/27/05	Issued for Permitting Use	11/-	Want 300	INC	MAKE
1	9/13/03	Issued for Permitting Use	Jessica Jackson	S. Suharto	Cliff Slater	Mark Hoffmann
0	12/17/03	Issued for Permitting Use	Jessica Jackson	Cliff Slater	N/A	Mark Hoffmann
REV	DATE	REASON FOR REVISION	PREPARER	CHECKER	REVIEWER	APPROVER

Sheet 1 of 5

ISSUED BY RPP-WTP PDC

DATA SHEET #: 24590-PTF-MVD-TCP-P0002, Rev 2





PLANT ITEM No. 24590-PTF-MV-TCP-VSL-00001

Materials of Construction

Component	<u>Material</u>	Minimum Thickness / Size	Containment
Top Head	SA 240 316 with max. Carbon of 0.030 %	See Drawing	Auxiliary (See Note 1)
Shell	SA 240 316 with max. Carbon of 0.030 %	See Drawing	Primary (See Note 1)
Bottom Head	SA 240 316 with max. Carbon of 0.030 %	See Drawing	Primary (See Note 1)
Support (Skirt)	SA 240 304 with max. Carbon of 0.030 %	See Drawing	NIA
Jacket/Coils/Half-Pipe Jacket	NIA	N/A	NIA
Internals	SA240 316 with max. Carbon of 0.030 %	See Drawing	Thermowell Primary (See Note 1)
Pipe	SA312 TP316 Seamless with max. Carbon of 0.030 %; SB622 UNS N10276 (only for nozzle neck and dip pipe for Nozzle N02)	See Drawing	See Note-1
Forgings/ Bar stock	SA182 F316 with max. Carbon of 0.030 %	See Drawing	As Note-1 for Nozzle Necks
Gaskets	NIA	NIA	NIA
Bolting	NIA	NIA	NIA

Miscellaneous Data

Orientation	Vertical	Support Type	Skirt
Insulation Function	Not Applicable	Insulation Material	Not Applicable
Insulation Thickness (inch)	Not Applicable	Welds Surface Finish	De-scaled as laid

Remarks

* To be determined by the vendor.

Note 1: All welds forming part of the primary and auxiliary containment including nozzle attachment welds shall be subjected to 100% volumetric examination.

Note 2: Deleted.

Note 3: Vessel volumes are approximate and do not account for manufacturing tolerances, nozzles, and displacement of internals.

Note 4: Contents of this document are Pangerous Waste Permit affecting.

Note 5: This vessel is in a Black Cell./2

Note 6: Deleted/2

Note 7: BNI shall ensure that an additional 0.164^n is available for erosion in the bottom head and the Seller shall report the minimum thickness required for all specified loading conditions, exclusive of erosion and corrosion allowances.

Note 8: BNI shall ensure that an additional 0.113" is available for erosion in the lower 4" of the interior conical surface of the pulse jet mixers. $\frac{1}{2}$

Note 9: All hydrodynamic loads are for BNI internal use only and are to be disregarded. $\frac{1}{2}$



Life Cycle Description

MECHANICAL DATA SHEET: VESSEL

PLANT ITEM No. 24590-PTF-MV-TCP-VSL-00001

Equipment Cyclic Data Sheet

Plant Item Number	24590-PTF-MV-TCP-VSL-00001
Component Description	Parent Vessel
The information below	is provisional and envelopes operational duty for fatigue assessment. It is not to be used as operational data.
Materials of Construction	SA 240 316 with max. Carbon of 0.030 %
Design Life	40 years
Component Function and	This vessel receives and stores treated LAW concentrate. It suspends solids for transfer and to facilitate heat

transfer. It maintains a minimum temperature to avoid precipitation of concentrate. Vessel is emptied every six

Load Type		Max	Number of Cycles	Comment
psig	-8	15	10	Nominal assumption
psig	-0.22/2	0	2500	·
°F	77	212/2	2500	Uniform material temperature range, not between two points
Contents Specific Gravity		1.57/2	2080	Nominal assumption
inch	24	399	2500	Coincident with pressure cycles
es			1	
Nozzles			As above	
	psig °F vity	psig -0.22/2 °F 77 vity 1.0 inch 24 res Within 50°F of	psig -8 15 psig -0.22/2 0 °F 77 212/2 vity 1.0 1.57/2 inch 24 399	psig -8 15 10 psig -0.22 0 2500 °F 77 212 2500 vity 1.0 1.57 2 2080 inch 24 399 2500 res Within 50°F of vessel As above


Hydrodynamic Loading (Notes 6 & 9) 2

In normal operation, pulse jet mixers discharge liquid into the parent vessel imposing a cyclical hydrodynamic load on all internal components. Occasionally, an upset condition designated 'overblow' causes air to be discharged from any single pulse jet mixer. All internal components shall be designed for the combination of the normal operational hydrodynamic loads and overblow loads, and this load combination is also to be assumed to act concurrently with seismic loads.

days. Washdown is once per year.

The following table indicates the normal hydrodynamic pressure for at ranges of elevations in the vessel and the number of design cycles for each condition. The hydrodynamic forces cycle between the indicated pressure ranges applied across the projected area of the component. Positive hydrodynamic forces act in the radial, outward direction and the vertical, upward direction. Seller shall apply the radial load simultaneously in the radial direction and normal to the radial direction in the horizontal plane.


Normal Operation Hydrodynamic Pressure Range, psi						
Eleva	tion A	Elevation B		Elevation C		Cycles
Radial	Vertical	Radial	Vertical	Radial	<u>Vertical</u>	
-0.15 to 0.25	-0.15 to 0.15	-0.05 to 0.12	-0.15 to 0.15	-0.03 to 0.05	-0.06 to 0.15	3.9 X 10°





PLANT ITEM No. 24590-PTF-MV-TCP-VSL-00001

Overblow loads vary as a function of the distance from the center of the overblowing pulse jet mixer nozzle and the elevation 'H' above the overblowing pulse jet mixer nozzle as plotted:



The overblow pressure shall only be applied to the projected area of the overblowing pulse jet mixer in the vertical, upward direction and to all surrounding components in the horizontal plane, radiating from the overblowing pulse jet mixer. Seller shall consider that any single pulse jet mixer may overblow 100 cycles.

Notes

- Cycle increase: The Seller must increase the numbers of operational cycles given above by 10% to account for commissioning duty unless otherwise noted.
- Nozzle N02 and the associated dip pipe shall be fatigue assessed/analyzed for 2500 temperature/pressure cycles from 0 psig at 59 F to 15 psig at 353 F, the pressure cycles shall coincide with the temperature cycles.



PLANT ITEM No. 24590-PTF-MV-TCP-VSL-00001

Equipment Cyclic Data Sheet

Plant Item Number	TCP-PJM-00001, TCP-PJM-00002, TCP-PJM-00003, TCP-PJM-00004, TCP-PJM-00005,
	TCP-PJM-00006, TCP-PJM-00007, TCP-PJM-00008
Component Description	Pulse Jet Mixers

The information below is provisional and envelopes operational duty for fatigue assessment. It is not to be used as operational data.					
Materials of Construction	SA 240 316 with max. Carbon of 0.030 %				
Design Life	40 years				
Component Function and Life Cycle Description	These pulse jet mixers (PJMs) are cyclically loaded using vacuum to fully fill the PJMs with process liquid and compressed air to fully empty the PJMs. The pulse jet mixers are contained within a parent vessel with varying liquid level. They shall be designed to cycle between the maximum design pressure and the minimum design pressure plus the external static head imposed by the parent vessel. The pulse jet mixer supports shall be designed to cycle between fully buoyant (pulse jet mixer empty and parent vessel full) and fully loaded (pulse jet mixer full and parent vessel empty) in addition to thrust.				

Load Type		Min	Max	Number of Cycles	Comment
Design Pressure	psig	FV	83	10	Nominal assumption
Operating Pressure	psig	FV	58	3.9 X 10 ⁶	
Operating Temperature	°F	77	212/2	3.9 X 10 ⁶	Pressure cycles to be at 212° F and non-coincident with temperature cycles. The range given is uniform material temperature range, not between adjacent points.
Contents Specific Gravity		1.0	1.57 /2	2080	Nominal assumption
Contents Level	inch	Empty	Flooded	3.9 X 10 ⁶	Coincident with pressure cycles
Localized Featur	es				
Supports		As above		As above with contents level changing coincident with pressure cycles.	
	· .				
		1			

Notes

•	Cycle increase: The Seller must increase the numbers of operational cycles given above by 10% to account for commissioning duty
	unless otherwise noted